

Page 1 of 40  
Sabey Data Center  
Properties, LLC  
Permit No. CQ-010

Issuance Date: TBD  
Effective Date: TBD  
Expiration Date: TBD

## City of Quincy Waste Discharge Permit Number CQ-010

City of Quincy

Quincy, Washington 99948

In compliance with the provisions of the  
State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington, as amended,

Sabey Data Center Properties, LLC  
2200 M Street N.E.  
Quincy, WA. 98848

is authorized to discharge wastewater in accordance with the special and general conditions which follow.

Facility Location: 2200 M St N.E. Quincy, WA. 98848	SIC Code: 7374
Industry Type: Data Center POTW Receiving Discharge: City of Quincy's MWRF	Significant Industrial User

---

Paul Worley  
City Mayor  
Quincy, Washington

## Table of Contents

<i>Summary of Permit Report Submittals</i> .....	4
<i>Special Conditions</i> .....	5
<b>S1. Discharge limits</b> .....	<b>5</b>
<b>S2. Monitoring requirements</b> .....	<b>6</b>
S2.A. Monitoring requirements .....	6
S2.B. Sampling and analytical procedures .....	8
S2.C. Flow measurement, and continuous monitoring devices.....	8
S2.D. Laboratory accreditation.....	8
S2.E. Request for reduction in monitoring.....	9
<b>S3. Reporting and recording requirements</b> .....	<b>9</b>
S3.A. Reporting .....	9
S3.B. Records retention.....	11
S3.C. Recording of results .....	11
S3.D. Additional monitoring by the Permittee .....	11
S3.E. Reporting permit violations .....	11
S3.F. Other reporting .....	14
S3.G. Maintaining a copy of this permit.....	14
S3.H. Dangerous waste discharge notification .....	14
S3.I. Spill notification .....	14
<b>S4. Operation and maintenance</b> .....	<b>14</b>
S4.A. Operations and maintenance manual.....	15
S4.B. Bypass procedures.....	15
<b>S5. Prohibited discharges</b> .....	<b>18</b>
S5.A. General prohibitions .....	18
S5.B. Specific prohibitions.....	18
S5.C. Prohibited unless approved.....	19
<b>D6. Dilution prohibited</b> .....	<b>19</b>
<b>S7. Application for permit renewal or modification for facility changes</b> .....	<b>19</b>
<b>S8. Non-routine and unanticipated discharges</b> .....	<b>19</b>
<i>General Conditions</i> .....	<b>20</b>

<b>G1.</b>	<b>Signatory requirements .....</b>	<b>20</b>
<b>G2.</b>	<b>Right of entry.....</b>	<b>21</b>
<b>G3.</b>	<b>Permit actions.....</b>	<b>21</b>
<b>G4.</b>	<b>Reporting a cause for modification .....</b>	<b>22</b>
<b>G5.</b>	<b>Plan review required.....</b>	<b>22</b>
<b>G6.</b>	<b>Compliance with other laws and statutes .....</b>	<b>22</b>
<b>G7.</b>	<b>Transfer of this permit .....</b>	<b>22</b>
<b>G8.</b>	<b>Reduced production for compliance .....</b>	<b>23</b>
<b>G9.</b>	<b>Removed substances .....</b>	<b>23</b>
<b>G10.</b>	<b>Payment of fees.....</b>	<b>23</b>
<b>G11.</b>	<b>Penalties for violating permit conditions .....</b>	<b>23</b>
<b>G12.</b>	<b>Duty to provide information .....</b>	<b>24</b>
<b>G13.</b>	<b>Duty to comply .....</b>	<b>24</b>
<i>Appendix A</i>	<i>.....</i>	<i>25</i>

## Summary of Permit Report Submittals

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.A.	Discharge Monitoring Report	Monthly	<a href="#">April 20, 2020</a>
S3.E	Reporting Permit Violations	As necessary	
S3.F	Other Reporting	As necessary	
S4.A.	Operation and Maintenance Manual	1/permit cycle	<a href="#">November 1, 2021</a>
S4.A.	O&M Manual Update or Review Confirmation Letter	Annually	<a href="#">November 1, 2022</a>
S4.B	Reporting Bypasses	As necessary	
S7.	Application for Permit Renewal	1/permit cycle	<a href="#">November 1, 2025</a>

## Special Conditions

### S1. Discharge limits

All discharges and activities authorized by this permit must comply with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit violates the terms and conditions of this permit.

A discharge of a pollutant in excess of local limits set by City of Quincy violates the terms and conditions of this permit.

Beginning on the effective date, the Permittee is authorized to discharge wastewater to City of Quincy, Municipal Reclaim Wastewater Treatment Facility sewer system subject to the following limits:

Effluent Limits:		
Latitude <a href="#">47.2469</a> Longitude <a href="#">119.8130</a>		
Parameter	Average Monthly <sup>a</sup>	Maximum Daily <sup>b</sup>
Flow	-----	250,000 gpd
Biochemical Oxygen Demand (BOD <sub>5</sub> )	-----	300 mg/L
Total Suspended Solids (TSS)	-----	300 mg/L
Chlorine, Total Residual	-----	20 mg/L
TDS	-----	5000 mg/L
Arsenic	-----	0.059 mg/L
Cadmium	-----	0.031 mg/L
Copper	-----	1.12 mg/L
Lead	-----	0.21 mg/L
Mercury	-----	0.012 mg/L
Molybdenum	-----	0.040 mg/L
Nickel	-----	0.38 mg/L
Selenium	-----	0.048
Zinc	-----	2.12
Parameter	Minimum	Maximum

Parameter	Minimum	Maximum
pH	5.0	11.0

<sup>a</sup>	Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured.
<sup>b</sup>	Maximum daily effluent limit means the highest allowable daily discharge. The daily discharge means the discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. For other units of measurement, the daily discharge is the average measurement of the pollutant over the day. This does not apply to pH.

## S2. Monitoring requirements

### S2.A. Monitoring requirements

The Permittee must monitor Flow and pH in accordance with the following schedule and the requirements specified in Appendix A.

Parameter	Units	Sampling Point	Sampling Frequency	Sample Type
Flow	g.p.d.	effluent meter	Continuous <sup>1</sup>	Metered
pH	s.u.	pH meter	1/week	Metered
BOD <sub>5</sub>	mg/L; lbs	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
TSS	mg/L; lbs	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
TDS	mg/L; lbs	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
Chlorine, Total Residual	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
Sodium	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
NH <sub>3</sub> (as N)	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
TKN (as N)	mg/L; lbs	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
NO <sub>3</sub> (as N)	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>

Parameter	Units	Sampling Point	Sampling Frequency	Sample Type
Chloride (Cl)	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
Phosphorus (as P)	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
Magnesium	mg/L	effluent from cooling tower	1/month	24 hr. composite <sup>2</sup>
Total Arsenic (As)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Cadmium (Cd)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Copper (Cu)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Lead (Pb)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Mercury (Hg)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Molybdenum (Mo)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Nickel (Ni)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Selenium (Se)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>
Total Zinc (Zn)	,ug/L	effluent from cooling tower	4/year <sup>3</sup>	24 hr. composite <sup>2</sup>

1	Continuous means uninterrupted except for brief lengths of time for calibration, for power failure, or for unanticipated equipment repair or maintenance. The Permittee must sample hourly when continuous monitoring is not possible.
2	24-hour composite means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.
3	March, June, September, December

**S2.B. Sampling and analytical procedures**

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit must conform to the latest revision of the following rules and documents unless otherwise specified in this permit or approved in writing by the City.

- Guidelines Establishing Test Procedures for the Analysis of Pollutants contained in 40 CFR Part 136
- Standard Methods for the Examination of Water and Wastewater (APHA)

**S2.C. Flow measurement, and continuous monitoring devices**

The Permittee must:

1. Select and use appropriate flow measurement, and continuous monitoring devices and methods consistent with accepted scientific practices.
2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard and the manufacturer's recommendation for that type of device.
3. Calibrate continuous monitoring instruments weekly unless it can demonstrate a longer period is sufficient based on monitoring records. The Permittee:
  - a. Must calibrate continuous pH measurement instruments using a grab sample analyzed in the lab with a pH meter calibrated with standard buffers and analyzed within 15 minutes of sampling.
4. Use field measurement devices as directed by the manufacturer and do not use reagents beyond their expiration dates.
5. Calibrate these devices at the frequency recommended by the manufacturer.
6. Calibrate flow-monitoring devices at a minimum frequency of at least one calibration per year.
7. Maintain calibration records for at least three years.

**S2.D. Laboratory accreditation**

The City of Quincy will be responsible for all monitoring data required for this permit. Specified parameters must be prepared by a laboratory registered or accredited under the provisions of chapter 173-50 WAC, *Accreditation of Environmental Laboratories*. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement.



### **S2.E. Request for reduction in monitoring**

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. The City will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

## **S3. Reporting and recording requirements**

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to the City is a violation of the terms and conditions of this permit.

### **S3.A. Reporting**

The first monitoring period begins on the effective date of the permit. The Permittee must:

Summarize, report, and submit monitoring data obtained during each monitoring period on the Discharge Monitoring Report (DMR) provide by the City, Include data for each of the parameters tabulated in Special Condition S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable).

Monitoring data obtained during the previous month shall be summarized and reported on a form provided, or otherwise approved, by the City, and be received no later than the **20<sup>th</sup>** day of the month following the completed reporting period, unless otherwise specified in this permit.

2. Enter the “no discharge” reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.
3. Report single analytical values below detection as “less than the detection level (DL)” by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and quantitation level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.

4. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in Appendix A.
5. Calculate average values (unless otherwise specified in the permit) using:
  - a. The reported numeric value for all parameters measured between the agency-required detection value and the agency-required quantitation value.
  - b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample for the reporting period.
  - c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
6. Report single-sample grouped parameters (for example priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WAWebDMR form and include: sample date, concentration detected, detection limit (DL) (as necessary), and laboratory quantitation level (QL) (as necessary). The Permittee must also submit an electronic PDF copy of the laboratory report. The Permittee must submit a paper copy of the laboratory report providing the following information: date sampled, sample location, date of analysis, parameter name, CAS number, analytical method/number, detection limit (DL), laboratory quantitation level (QL), reporting units, and concentration detected.

The contract laboratory reports must also include information on the chain of custody, QA/QC results, and documentation of accreditation for the parameter.
7. Ensure that DMR forms are postmarked or received by the City no later than the dates specified below, unless otherwise specified in this permit.
8. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below. The Permittee must:
  - a. Submit **monthly** DMRs by the **20<sup>th</sup>** day of the following month.
  - b. Submit permit renewal application monitoring data in a report by November 1, 2025.
9. Submit DMR reports to the City at:

Industrial Pretreatment Coordinator  
City of Quincy  
PO Box 1249  
Quincy, WA 98848

**S3.B. Records retention**

The Permittee must retain records of all monitoring information for a minimum of three (3) years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the City.

**S3.C. Recording of results**

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement
2. The individual who performed the sampling or measurement
3. The dates the analyses were performed
4. The individual who performed the analyses
5. The analytical techniques or methods used
6. The results of all analyses

**S3.D. Additional monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Condition S2.

**S3.E. Reporting permit violations**

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to the City within thirty (30) days of sampling.

**a. Immediate reporting**

The Permittee must report any noncompliance that may endanger health or the environment immediately to the City and Department of Ecology's Regional Office 24-hr. number listed below:

City of Quincy	509-237-2943
Eastern Regional Office	509-329-3400

**b. Twenty-four-hour reporting**

The Permittee must report the following occurrences of noncompliance by telephone, to the City at the telephone numbers listed above, within 24 hours from the time the Permittee becomes aware of any of the following circumstances. The Permittee must report:

1. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
2. Any unanticipated bypass that causes an exceedance of an effluent limit in the permit (See Part S4.B., "Bypass Procedures").
3. Any upset that causes an exceedance of an effluent limit in the permit. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
4. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Section S1 of this permit.
5. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit.

**c. Report within five days**

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above. The report must contain:

1. A description of the noncompliance and its cause.
2. The period of noncompliance, including exact dates and times.
3. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
5. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

**d. Waiver of written reports**

The City may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

**e. All other permit violation reporting**

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A ("Reporting"). The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

**f. Report submittal**

The Permittee must submit reports to the address listed below

Industrial Pretreatment Coordinator  
City of Quincy  
PO Box 1249  
Quincy, WA 98848

**S3.F. Other reporting**

**a. Spills of Oil or Hazardous Materials**

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of RCW 90.56.280 and chapter 173-303-145. You can obtain further instructions at the following website:

<http://www.ecy.wa.gov/programs/spills/other/reportaspill.htm> .

**b. Failure to submit relevant or correct facts**

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the City, it must submit such facts or information promptly.

**S3.G. Maintaining a copy of this permit**

The Permittee must keep a copy of this permit at the facility and make it available upon request to City inspectors.

**S3.H. Dangerous waste discharge notification**

The Permittee must notify the publicly owned treatment works (POTW) and the City in writing of the intent to discharge into the POTW any substance designated as a dangerous waste in accordance with the provisions of WAC 173-303-070. It must make this notification at least 90 days prior to the date that it proposes to initiate the discharge. The Permittee must not discharge this substance until authorized by the City and the POTW. It must also comply with the notification requirements of Special Condition S8 and General Condition G4.

**S3.I. Spill notification**

The Permittee must notify the POTW immediately (as soon as discovered) of all discharges that could cause problems to the POTW, such as process spills and unauthorized discharges (including slug discharges).

**S4. Operation and maintenance**

The Permittee must, at all times, properly operate and maintain all facilities or systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

**S4.A. Operations and maintenance manual**

**a. O&M manual submittal and requirements**

The Permittee must:

1. Prepare an “or” Update the Operations and Maintenance (O&M) Manual that meets the requirements of WAC 173-240-150 and submit it to the City for approval by November 1, 2021
2. Review the O&M Manual at least annually and confirm this review by letter to the City by November 1 of each year.
3. Submit to the City for review and approval substantial changes or updates to the O&M Manual whenever it incorporates them into the manual.
4. Keep the approved O&M Manual at the permitted facility.
5. Follow the instructions and procedures of this manual.

**b. O&M manual components**

In addition to the requirements of WAC 173-240-150(1) and (2), the O&M manual must include:

1. Emergency procedures for plant shutdown and cleanup in event of wastewater system upset, spill, failure, or demand by the publicly owned treatment works (POTW) treating the discharge.
2. Wastewater system maintenance procedures that contribute to the generation of process wastewater.
3. Any directions to maintenance staff when cleaning, or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (for example, defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine.)
4. Wastewater sampling protocols and procedures for compliance with the sampling and reporting requirements in the wastewater discharge permit.
5. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
6. Treatment plant process control monitoring schedule.

**S4.B. Bypass procedures**

This permit prohibits a bypass, which is the intentional diversion of waste streams from any portion of a treatment facility. The City may take enforcement action against a Permittee for a bypass unless one of the following circumstances (1, 2, or 3) applies.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

This permit authorizes a bypass if it allows for essential maintenance and does not have the potential to cause violations of limits or other conditions of this permit, or adversely impact public health as determined by the City prior to the bypass. The Permittee must submit prior notice, if possible, at least ten (10) days before the date of the bypass.

2. Bypass is unavoidable, unanticipated, and results in noncompliance of this permit.

This permit authorizes such a bypass only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
- b. No feasible alternatives to the bypass exist, such as:
  - The use of auxiliary treatment facilities.
  - Retention of untreated wastes.
  - Stopping production.
  - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass.
  - Transport of untreated wastes to another treatment facility.
- c. The Permittee has properly notified the City of the bypass as required in Condition S3.E of this permit.

3. If bypass is anticipated and has the potential to result in noncompliance of this permit.

- a. The Permittee must notify the City at least thirty (30) days before the planned date of bypass. The notice must contain:
  - A description of the bypass and its cause.
  - An analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing.
  - A cost-effectiveness analysis of alternatives including comparative resource damage assessment.
  - The minimum and maximum duration of bypass under each alternative.



- A recommendation as to the preferred alternative for conducting the bypass.
  - The projected date of bypass initiation.
  - A statement of compliance with SEPA.
  - A request for modification of water quality standards as provided for in WAC 173-201A-410, if an exceedance of any water quality standard is anticipated.
  - Details of the steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify the City of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during preparation of the engineering report or facilities plan and plans and specifications and must include these to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.
- c. The City will consider the following prior to issuing an administrative order for this type of bypass:
- If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
  - If feasible alternatives to bypass exist, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
  - If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the City will approve or deny the request. The City will give the public an opportunity to comment on bypass incidents of significant duration, to the extent feasible. The City will approve a request to bypass by issuing an administrative order under RCW 90.48.120.

## **S5. Prohibited discharges**

The Permittee must comply with these General and Specific Prohibitions.

### **S5.A. General prohibitions**

The Permittee must not introduce into the POTW pollutant(s), which cause Pass Through or Interference.

### **S5.B. Specific prohibitions**

In addition, the Permittee must not introduce the following into the POTW:

1. Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, waste streams with a closed cup flashpoint of less than 60 degrees C (140 degrees F) using the test methods specified in 40 CFR 261.21
2. Solid or viscous pollutants in amounts, which will cause obstruction to the flow in the POTW resulting in interference
3. Any pollutant (including oxygen-demanding pollutants (BOD<sub>5</sub>, etc.), released in a discharge at a flow rate and/or pollutant concentration that will cause interference with the POTW
4. Heat in amounts which will inhibit biological activity in the POTW resulting in interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 degrees C (104 degrees F) unless the approval authority, upon request of the POTW, approves alternative temperature limits
5. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems
7. Any trucked or hauled pollutants, except at discharge points designated by the POTW
8. Pollutants that will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0 or greater than 11.0, unless the collection and treatment system is specifically designed to accommodate such discharges.

### **S5.C. Prohibited unless approved**

Any of the following discharges are prohibited unless approved by the City under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or a need to augment sewage flows due to septic conditions):

1. Noncontact cooling water in significant volumes
2. Storm water and other direct inflow sources
3. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system
4. The discharge of dangerous wastes as defined in Chapter 173-303 WAC (Unless specifically authorized in this permit)

### **D6. Dilution prohibited**

The Permittee must not dilute the wastewater discharge with stormwater or increase the use of potable water, process water, noncontact cooling water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limits contained in this permit.

### **S7. Application for permit renewal or modification for facility changes**

The Permittee must submit an application for renewal of this permit by **November 1, 2025**. The Permittee must submit a paper copy and an electronic copy (preferably as a PDF).

The Permittee must also submit a new application or supplement at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

### **S8. Non-routine and unanticipated discharges**

1. Beginning on the effective date of this permit, the Permittee is authorized to discharge non-routine wastewater on a case-by-case basis to the sanitary sewer if approved by the City and the POTW. Prior to any such discharge, the Permittee must contact the City and **at a minimum** provide the following information:
  - a. The proposed discharge location
  - b. The nature of the activity that will generate the discharge
  - c. Any alternatives to the discharge, such as reuse, storage, or recycling of the water

- d. The total volume of water it expects to discharge
  - e. The results of the chemical analysis of the water
  - f. The date of proposed discharge
  - g. The expected rate of discharge discharged, in gallons per day
2. The expected rate of discharge in gallons per minute for discharges greater than 20,000 gallons
  3. The Permittee must analyze the water for all constituents limited for the discharge and report them as required by subpart 1.e above. The analysis must also include any parameter deemed necessary by the City. All discharges must comply with the effluent limits as established in Condition S1 of this permit and any other limits imposed by the City.
  4. The discharge cannot proceed until the City has reviewed the information provided and has authorized the discharge by letter to the Permittee or by an Administrative Order.

## **General Conditions**

### **G1. Signatory requirements**

All applications, reports, or information submitted to the City must be signed as follows:

1. All permit applications must be signed by either a principal executive officer or ranking elected official.
2. All reports required by this permit and other information requested by the City must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by the person described above and is submitted to the City at the time of authorization, and
  - b. The authorization specifies either a named individual or any individual occupying a named position.
3. Changes to authorization. If an authorization under paragraph G1.2. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the City prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this section must make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

## **G2. Right of entry**

Representatives of the City have the right to enter at all reasonable times in or upon any property, public or private, for the purpose of inspecting and investigating conditions relating to the pollution or the possible pollution of any waters of the state. Reasonable times include normal business hours; hours during which production, treatment, or discharge occurs; or times when the City suspects a violation requiring immediate inspection. Representatives of the City must be allowed to have access to, and copy at reasonable cost, any records required to be kept under terms and conditions of the permit; to inspect any monitoring equipment or method required in the permit; and to sample the discharge, waste treatment processes, or internal waste streams.

## **G3. Permit actions**

This permit is subject to modification, suspension, or termination, in whole or in part by the City for any of the following causes:

1. Violation of any permit term or condition;
2. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
3. A material change in quantity or type of waste disposal;
4. A material change in the condition of the waters of the state; or
5. Nonpayment of fees assessed pursuant to Quincy Municipal Code 13.13.535.

The City may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

#### **G4. Reporting a cause for modification**

The Permittee must submit a new application, or a supplement to the previous application, along with required engineering plans and reports, whenever a new or increased discharge or change in the nature of the discharge is anticipated which is not specifically authorized by this permit. This application must be submitted at least one hundred eighty (180) days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

#### **G5. Plan review required**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to the City for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications should be submitted at least 180 days prior to the planned start of construction. Facilities must be constructed and operated in accordance with the approved plans.

#### **G6. Compliance with other laws and statutes**

Nothing in the permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

#### **G7. Transfer of this permit**

This permit is automatically transferred to a new owner or operator if:

1. A written agreement between the old and new owner or operator containing a specific date for transfer of permit responsibility, coverage, and liability is submitted to the City;
2. A copy of the permit is provided to the new owner and;
3. The City does not notify the Permittee of the need to modify the permit.

Unless this permit is automatically transferred according to Section 1. above, this permit may be transferred only if it is modified to identify the new Permittee and to incorporate such other requirements as determined necessary by the City.

**G8. Reduced production for compliance**

The Permittee must control production or discharge to the extent necessary to maintain compliance with the terms and conditions of this permit upon reduction of efficiency, loss, or failure of its treatment facility until the treatment capacity is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power for the treatment facility is reduced, lost, or fails.

**G9. Removed substances**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the effluent stream for discharge.

**G10. Payment of fees**

The Permittee must submit payment of fees associated with this permit as assessed by the City. The City may revoke this permit if the permit fees established under Quincy Municipal Code 13.15.730 are not paid.

**G11. Penalties for violating permit conditions**

Any person who is found guilty of willfully violating the terms and conditions of this permit is guilty of a crime, and upon conviction thereof shall be punished by a fine as defined in Quincy Municipal Code 13.13.300 and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs is a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit incurs, in addition to any other penalty as provided by law, a civil penalty as defined in Quincy Municipal Code 13.13.300 for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is a separate and distinct violation.

## **G12. Duty to provide information**

The Permittee must submit to the City, within a reasonable time, all information which the City may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to the City upon request, copies of records required to be kept by this permit.

## **G13. Duty to comply**

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of chapter 90.48 RCW and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.



## **Appendix A**

### ***LIST OF POLLUTANTS WITH ANALYTICAL METHODS, DETECTION LIMITS AND QUANTITATION LEVELS***

The Permittee must use the specified analytical methods, detection limits (DLs) and quantitation levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136.

If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a quantitation limit (QL) to Ecology with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

The City added this appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

### **CONVENTIONAL PARAMETERS**

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <math>\mu\text{g/L}</math> unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> <math>\mu\text{g/L}</math> unless specified</b>
Biochemical Oxygen Demand	SM5210-B		2 mg/L
Soluble Biochemical Oxygen Demand	SM5210-B <sup>3</sup>		2 mg/L
Chemical Oxygen Demand	SM5220-D		10 mg/L
Total Organic Carbon	SM5310-B/C/D		1 mg/L
Total Suspended Solids	SM2540-D		5 mg/L
Total Ammonia (as N)	SM4500-NH3-B and C/D/E/G/H		20
Flow	Calibrated device		
Dissolved oxygen	SM4500-OC/OG		0.2 mg/L
Temperature (max. 7-day avg.)	Analog recorder or Use micro-recording devices known as thermistors		0.2° C
pH	SM4500-H <sup>+</sup> B	N/A	N/A

### **NONCONVENTIONAL PARAMETERS**

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <math>\mu\text{g/L}</math> unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> <math>\mu\text{g/L}</math> unless specified</b>
Total Alkalinity	SM2320-B		5 mg/L as CaCO <sub>3</sub>
Chlorine, Total Residual	SM4500 Cl G		50.0
Color	SM2120 B/C/E		10 color units

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Fecal Coliform	SM 9221E,9222	N/A	Specified in method - sample aliquot dependent
Fluoride (16984-48-8)	SM4500-F E	25	100
Nitrate + Nitrite Nitrogen (as N)	SM4500-NO3- E/F/H		100
Nitrogen, Total Kjeldahl (as N)	SM4500-N <sub>org</sub> B/C and SM4500NH <sub>3</sub> -B/C/D/EF/G/H		300
Soluble Reactive Phosphorus (as P)	SM4500- PE/PF	3	10
Phosphorus, Total (as P)	SM 4500 PB followed by SM4500-PE/PF	3	10
Oil and Grease (HEM) (Hexane Extractable Material)	1664 A or B	1,400	5,000
Salinity	SM2520-B		3 practical salinity units or scale (PSU or PSS)
Settleable Solids	SM2540 -F		500 (or 1.0 mL/L)
Sulfate (as mg/L SO <sub>4</sub> )	SM4110-B		0.2 mg/L
Sulfide (as mg/L S)	SM4500-S <sup>2</sup> F/D/E/G		0.2 mg/L
Sulfite (as mg/L SO <sub>3</sub> )	SM4500-SO3B		2 mg/L
Total Coliform	SM 9221B, 9222B, 9223B	N/A	Specified in method - sample aliquot dependent
Total dissolved solids	SM2540 C		20 mg/L
Total Hardness	SM2340B		200 as CaCO <sub>3</sub>
Aluminum, Total (7429-90-5)	200.8	2.0	10
Barium Total (7440-39-3)	200.8	0.5	2.0

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)	EPA SW 846 8021/8260	1	2
Boron Total (7440-42-8)	200.8	2.0	10.0
Cobalt, Total (7440-48-4)	200.8	0.05	0.25
Iron, Total (7439-89-6)	200.7	12.5	50
Magnesium, Total (7439-95-4)	200.7	10	50
Molybdenum, Total (7439-98-7)	200.8	0.1	0.5
Manganese, Total (7439-96-5)	200.8	0.1	0.5
NWTPH Dx <sup>4</sup>	Ecology NWTPH Dx	250	250
NWTPH Gx <sup>5</sup>	Ecology NWTPH Gx	250	250
Tin, Total (7440-31-5)	200.8	0.3	1.5
Titanium, Total (7440-32-6)	200.8	0.5	2.5

**PRIORITY POLLUTANTS**

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
<b>METALS, CYANIDE &amp; TOTAL PHENOLS</b>			
Antimony, Total (7440-36-0)	200.8	0.3	1.0
Arsenic, Total (7440-38-2)	200.8	0.1	0.5
Beryllium, Total (7440-41-7)	200.8	0.1	0.5

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Cadmium, Total (7440-43-9)	200.8	0.05	0.25
Chromium (hex) dissolved (18540-29-9)	SM3500-Cr EC	0.3	1.2
Chromium, Total (7440-47-3)	200.8	0.2	1.0
Copper, Total (7440-50-8)	200.8	0.4	2.0
Lead, Total (7439-92-1)	200.8	0.1	0.5
Mercury, Total (7439-97-6)	1631E	0.0002	0.0005
Nickel, Total (7440-02-0)	200.8	0.1	0.5
Selenium, Total (7782-49-2)	200.8	1.0	1.0
Silver, Total (7440-22-4)	200.8	0.04	0.2
Thallium, Total (7440-28-0)	200.8	0.09	0.36
Zinc, Total (7440-66-6)	200.8	0.5	2.5
Cyanide, Total (57-12-5)	335.4	5	10
Cyanide, Weak Acid Dissociable	SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	SM4500-CN G	5	10
Phenols, Total	EPA 420.1		50

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
<b>ACID COMPOUNDS</b>			
2-Chlorophenol (95-57-8)	625	1.0	2.0

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
2,4-Dichlorophenol (120-83-2)	625	0.5	1.0
2,4-Dimethylphenol (105-67-9)	625	0.5	1.0
4,6-dinitro-o-cresol (534-52-1) (2-methyl-4,6,-dinitrophenol)	625/1625B	1.0	2.0
2,4 dinitrophenol (51-28-5)	625	1.0	2.0
2-Nitrophenol (88-75-5)	625	0.5	1.0
4-nitrophenol (100-02-7)	625	0.5	1.0
Parachlorometa cresol (59-50-7) (4-chloro-3-methylphenol)	625	1.0	2.0
Pentachlorophenol (87-86-5)	625	0.5	1.0
Phenol (108-95-2)	625	2.0	4.0
2,4,6-Trichlorophenol (88-06-2)	625	2.0	4.0

***PRIORITY POLLUTANTS (continued)***

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
<b>VOLATILE COMPOUNDS</b>			
Acrolein (107-02-8)	624	5	10
Acrylonitrile (107-13-1)	624	1.0	2.0

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>VOLATILE COMPOUNDS</b>			
Benzene (71-43-2)	624	1.0	2.0
Bromoform (75-25-2)	624	1.0	2.0
Carbon tetrachloride (56-23-5)	624/601 or SM6230B	1.0	2.0
Chlorobenzene (108-90-7)	624	1.0	2.0
Chloroethane (75-00-3)	624/601	1.0	2.0
2-Chloroethylvinyl Ether (110-75-8)	624	1.0	2.0
Chloroform (67-66-3)	624 or SM6210B	1.0	2.0
Dibromochloromethane (124-48-1)	624	1.0	2.0
1,2-Dichlorobenzene (95-50-1)	624	1.9	7.6
1,3-Dichlorobenzene (541-73-1)	624	1.9	7.6
1,4-Dichlorobenzene (106-46-7)	624	4.4	17.6
Dichlorobromomethane (75-27-4)	624	1.0	2.0
1,1-Dichloroethane (75-34-3)	624	1.0	2.0
1,2-Dichloroethane (107-06-2)	624	1.0	2.0
1,1-Dichloroethylene (75-35-4)	624	1.0	2.0
1,2-Dichloropropane (78-87-5)	624	1.0	2.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) (542-75-6) <sup>6</sup>	624	1.0	2.0

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>VOLATILE COMPOUNDS</b>			
Ethylbenzene (100-41-4)	624	1.0	2.0
Methyl bromide (74-83-9) (Bromomethane)	624/601	5.0	10.0
Methyl chloride (74-87-3) (Chloromethane)	624	1.0	2.0
Methylene chloride (75-09-2)	624	5.0	10.0
1,1,2,2-Tetrachloroethane (79-34-5)	624	1.9	2.0
Tetrachloroethylene (127-18-4)	624	1.0	2.0
Toluene (108-88-3)	624	1.0	2.0
1,2-Trans-Dichloroethylene (156-60-5) (Ethylene dichloride)	624	1.0	2.0
1,1,1-Trichloroethane (71-55-6)	624	1.0	2.0
1,1,2-Trichloroethane (79-00-5)	624	1.0	2.0
Trichloroethylene (79-01-6)	624	1.0	2.0
Vinyl chloride (75-01-4)	624/SM6200B	1.0	2.0



**PRIORITY POLLUTANTS (continued)**

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>BASE/NEUTRAL COMPOUNDS</b> (compounds in bold are Ecology PBTs)			
Acenaphthene (83-32-9)	625	0.2	0.4
Acenaphthylene (208-96-8)	625	0.3	0.6
Anthracene (120-12-7)	625	0.3	0.6
Benzidine (92-87-5)	625	12	24
Benzyl butyl phthalate (85-68-7)	625	0.3	0.6
Benzo(a)anthracene (56-55-3)	625	0.3	0.6
Benzo(b)fluoranthene (3,4-benzofluoranthene) (205-99-2) <sup>7</sup>	610/625	0.8	1.6
<b>Benzo(j)fluoranthene (205-82-3)</b> <sup>7</sup>	625	0.5	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) (207-08-9) <sup>7</sup>	610/625	0.8	1.6
<b>Benzo(r,s,t)pentaphene (189-55-9)</b>	625	0.5	1.0

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
<b>BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)</b>			
Benzo(a)pyrene (50-32-8)	610/625	0.5	1.0
Benzo(ghi)Perylene (191-24-2)	610/625	0.5	1.0
Bis(2-chloroethoxy)methane (111-91-1)	625	5.3	21.2
Bis(2-chloroethyl)ether (111-44-4)	611/625	0.3	1.0
Bis(2-chloroisopropyl)ether (39638-32-9)	625	0.3	0.6
Bis(2-ethylhexyl)phthalate (117-81-7)	625	0.1	0.5
4-Bromophenyl phenyl ether (101-55-3)	625	0.2	0.4
2-Chloronaphthalene (91-58-7)	625	0.3	0.6
4-Chlorophenyl phenyl ether (7005-72-3)	625	0.3	0.5
Chrysene (218-01-9)	610/625	0.3	0.6
<b>Dibenzo (a,h)acridine (226-36-8)</b>	610M/625M	2.5	10.0
<b>Dibenzo (a,j)acridine (224-42-0)</b>	610M/625M	2.5	10.0
Dibenzo(a-h)anthracene (53-70-3)(1,2,5,6-dibenzanthracene)	625	0.8	1.6
Dibenzo(a,e)pyrene (192-65-4)	610M/625M	2.5	10.0
Dibenzo(a,h)pyrene (189-64-0)	625M	2.5	10.0
3,3-Dichlorobenzidine (91-94-1)	605/625	0.5	1.0
Diethyl phthalate (84-66-2)	625	1.9	7.6

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <i>µg/L unless specified</i></b>	<b>Quantitation Level (QL)<sup>2</sup> <i>µg/L unless specified</i></b>
<b>BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)</b>			
Dimethyl phthalate (131-11-3)	625	1.6	6.4
Di-n-butyl phthalate (84-74-2)	625	0.5	1.0
2,4-dinitrotoluene (121-14-2)	609/625	0.2	0.4
2,6-dinitrotoluene (606-20-2)	609/625	0.2	0.4

***PRIORITY POLLUTANTS (continued)***

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <i>µg/L unless specified</i></b>	<b>Quantitation Level (QL)<sup>2</sup> <i>µg/L unless specified</i></b>
<b>BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)</b>			
Di-n-octyl phthalate (117-84-0)	625	0.3	0.6
1,2-Diphenylhydrazine (as Azobenzene) (122-66-7)	1625B	5.0	20
Fluoranthene (206-44-0)	625	0.3	0.6
Fluorene (86-73-7)	625	0.3	0.6
Hexachlorobenzene (118-74-1)	612/625	0.3	0.6
Hexachlorobutadiene (87-68-3)	625	0.5	1.0
Hexachlorocyclopentadiene (77-47-4)	1625B/625	0.5	1.0

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)</b>			
Hexachloroethane (67-72-1)	625	0.5	1.0
Indeno(1,2,3- <i>cd</i> )Pyrene (193-39-5)	610/625	0.5	1.0
Isophorone (78-59-1)	625	0.5	1.0
<b>3-Methyl cholanthrene (56-49-5)</b>	625	2.0	8.0
Naphthalene (91-20-3)	625	0.3	0.6
Nitrobenzene (98-95-3)	625	0.5	1.0
N-Nitrosodimethylamine (62-75-9)	607/625	2.0	4.0
N-Nitrosodi-n-propylamine (621-64-7)	607/625	0.5	1.0
N-Nitrosodiphenylamine (86-30-6)	625	0.5	1.0
<b>Perylene (198-55-0)</b>	625	1.9	7.6
Phenanthrene (85-01-8)	625	0.3	0.6
Pyrene (129-00-0)	625	0.3	0.6
1,2,4-Trichlorobenzene (120-82-1)	625	0.3	0.6

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <i>µg/L unless specified</i></b>	<b>Quantitation Level (QL)<sup>2</sup> <i>µg/L unless specified</i></b>
<b>DIOXIN</b>			
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (176-40-16) (2,3,7,8 TCDD)	1613B	1.3 pg/L	5 pg/L

***PRIORITY POLLUTANTS (continued)***

<b>Pollutant &amp; CAS No. (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> <i>µg/L unless specified</i></b>	<b>Quantitation Level (QL)<sup>2</sup> <i>µg/L unless specified</i></b>
<b>PESTICIDES/PCBs</b>			
Aldrin (309-00-2)	608	0.025	0.05
alpha-BHC (319-84-6)	608	0.025	0.05
beta-BHC (319-85-7)	608	0.025	0.05

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>PESTICIDES/PCBs</b>			
gamma-BHC (58-89-9)	608	0.025	0.05
delta-BHC (319-86-8)	608	0.025	0.05
Chlordane (57-74-9) <sup>8</sup>	608	0.025	0.05
4,4'-DDT (50-29-3)	608	0.025	0.05
4,4'-DDE (72-55-9)	608	0.025	0.05 <sup>10</sup>
4,4' DDD (72-54-8)	608	0.025	0.05
Dieldrin (60-57-1)	608	0.025	0.05
alpha-Endosulfan (959-98-8)	608	0.025	0.05
beta-Endosulfan (33213-65-9)	608	0.025	0.05
Endosulfan Sulfate (1031-07-8)	608	0.025	0.05
Endrin (72-20-8)	608	0.025	0.05
Endrin Aldehyde (7421-93-4)	608	0.025	0.05
Heptachlor (76-44-8)	608	0.025	0.05
Heptachlor Epoxide (1024-57-3)	608	0.025	0.05
PCB-1242 (53469-21-9) <sup>9</sup>	608	0.25	0.5
PCB-1254 (11097-69-1)	608	0.25	0.5
PCB-1221 (11104-28-2)	608	0.25	0.5
PCB-1232 (11141-16-5)	608	0.25	0.5
PCB-1248 (12672-29-6)	608	0.25	0.5
PCB-1260 (11096-82-5)	608	0.13	0.5

Pollutant & CAS No. (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> <i>µg/L unless specified</i>	Quantitation Level (QL) <sup>2</sup> <i>µg/L unless specified</i>
<b>PESTICIDES/PCBs</b>			
PCB-1016 (12674-11-2) <sup>9</sup>	608	0.13	0.5
Toxaphene (8001-35-2)	608	0.24	0.5

1. Detection level (DL) or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. Quantitation Level (QL) also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to (1, 2, or 5) x 10<sup>n</sup>, where n is an integer. (64 FR 30417).  
 ALSO GIVEN AS:  
 The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).
3. Soluble Biochemical Oxygen Demand method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 um (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. NWTPH Dx - Northwest Total Petroleum Hydrocarbons Diesel Extended Range – see <http://www.ecy.wa.gov/biblio/97602.html>
5. NWTPH Gx - Northwest Total Petroleum Hydrocarbons Gasoline Extended Range – see <http://www.ecy.wa.gov/biblio/97602.html>
6. 1, 3-dichloropropylene (mixed isomers) You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).

7. Total Benzofluoranthenes - Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.
8. Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 0.025/0.050.
9. PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.